Heidelberg Materials UK Second Floor, Arena Court, Crown Lane Maidenhead, Berkshire, SL6 8QZ Ketton Works 1333-CPR-00254





Cement Test Report

пешешегу ічіацепаіs Ketton

> Stamford PE9 3SX

Tel: 0330 123 2074 Fax: 01780 727008

Results of tests made at the laboratories of the company on samples of Ketton PLC 52,5N, BS EN 197-1:2011 - CEM II/A-LL 52,5N

Dispatched from Ketton during week ending and during week ending

21-Jan-24 (Week No. 2024-3

31-Dec-23 (Week No. 2023-52) for 28 day results

Date	Fineness	Setting Time	Soundness	Compressive Strength			Chloride	Alkali	
	Specific Surface (m²/kg)	Initial	Expansion	40mm x 40mm x 160mm Mortar prisms				Certified Average Alkali	Standard
		(mins)	(mm)	2 Days	7 Days	28 Days	%	% Na₂O eq	Deviation
				(N/mm ²)	(N/mm ²)	(N/mm ²)			
15-Jan-24	555	185	0	32.5	50.0		0.04	0.67	0.03
17-Jan-24	515	185	0	35.0	51.0		0.05	0.67	0.03
Average	535	185	0	34.0	50.5		0.05		0.03
Average									

Product Declaration:

Declared Mean Alkali (%) = 0.75 (Max) Declared Chloride content (%) = 0.07 (Max)

For and on behalf of HEIDELBERG MATERIALS UK

10 Cerdial Dr Nina Cardinal, Dipl.Ing., CEng, MiMMM

National Technical Manager Heidelberg Materials UK

Heidelberg Materials UK has used all reasonable care to ensure the information herein contained is accurate but to the extent permitted in law, no liability can be accepted by Heidelberg Materials UK for any loss, damage, cost or expense arising from any inaccuracy, whether due to negligence or otherwise.