

Conformity Certificate



Regen Ground Granulated Blastfurnace Slag Produced at Sample Period

Purfleet June 2024

Certificate of Conformity of Regen GGBS

Spot samples of Regen GGBS were taken and tested to determine conformity to the autocontrol requirements of EN 15167-1 "Ground granulated blastfurnace slag for use in concrete, mortar and grout" following the methods given in that standard. The values reported are mean values for the monthly production period.

		Result	EN Limit
Regen GGBS Only			
Fineness m ² /kg		456	min. 275
Magnesia MgO %		7	max. 18
Sulfate SO ³ %		0.20	max. 2.5
Sulfide S ²⁻ %		0.91	max. 2.0
Chloride Content Cl %		0.01	max. 0.1
Moisture Content %		0.02	max. 1.0
Aluminia Al ₂ O ₃ %		13	
Note: If the value is $\ge 14\%$ the '+SR' restriction will be exceeded if the C ₃	A of the CEM I is > 1	0%.	
Alkalis as Na2O equ. (acid sol	uble)		
Certified Average Alkali (Last 25) %		≤ 1.0	
Mean Alkali content (Last 25) %		0.54	
Declared Mean: Mean last 25 + (SD last 25 x 1.64) %		0.60	
Combination of 50% Laboratory Stock CEM I Portland (Cement and 50% Re	gen GGBS	•
Initial Setting Time min.		239	> 2 x PC
Activity Index %	7 days	67	min. 45
	28 days	89	min. 70
Laboratory Stock CEM I Portland Ce	ement Only		
The laboratory stock CEM I Portland cement used in these	tests was supplied b	y Hanson.	
Initial Setting Time min		130	
Compressive Strength N/mm ²	7 days	44.5	
	28 days	55.4	
The Regen GGBS contained no additional materials other than those processes demonstrate the conformity of the material sold during the mont			

demonstrate the conformity of the material sold uring the month to the requirements of EN 15167-1.

Tredenority waterials out to the state in the minimator meters of the requirements of the state permitted in raw, no liability can be accepted by Heidelberg Materials UK for any loss, damage, cost or expense arising from any inaccuracy, whether due to negligence

Signed:

Dr Nina Cardinal, Dipl.Ing., CEng, MICT National Technical Manager

CF

1333-CPR-00133