

## **Conformity Certificate**



## Regen Ground Granulated Blastfurnace Slag Produced at Sample Period

Port Talbot August 2024

## **Certificate of Conformity of Regen GGBS**

Spot samples of Regen GGBS were taken and tested to determine conformity to the autocontrol requirements of EN 15167-1 "Ground granulated blastfurnace slag for use in concrete, mortar and grout" following the methods given in that standard. The values reported are mean values for the monthly production period.

		Desuit	L ENLIGHT
		Result	EN Limit
Regen GGBS Only			
Fineness m <sup>2</sup> /kg		442	min. 275
Magnesia MgO %		8	max. 18
Sulfate SO <sup>3</sup> %		0.40	max. 2.5
Sulfide S <sup>2-</sup> %		1.07	max. 2.0
Chloride Content CI %		0.01	max. 0.1
Moisture Content %		0.18	max. 1.0
Aluminia Al₂O₃ %		13	
Note: If the value is $\geq$ 14% the '+SR' restriction will be exceeded if the C <sub>3</sub> A o	f the CEM I is > 10	%.	
Alkalis as Na2O equ. (acid solubl	e)		
Certified Average Alkali (Last 25) %		≤ 1.0	
Mean Alkali content (Last 25) %		0.66	
Declared Mean : Mean last 25 + (SD last 25 x 1.64) %		0.73	
Combination of 50% Laboratory Stock CEM I Portland Cen	nent and 50% Reg	en GGBS	
Initial Setting Time min.		223	> 2 x PC
Activity Index %	7 days	63	min. 45
	28 days	87	min. 70
Laboratory Stock CEM I Portland Ceme	ent Only		
The laboratory stock CEM I Portland cement used in these tests was s	supplied by Heidelb	erg Materia	ls UK.
Initial Setting Time min		139	
Compressive Strength N/mm <sup>2</sup>	7 days	46.4	
	28 days	58.6	
The Regen GGBS contained no additional materials other than those perm demonstrate the conformity of the material sold during the month to melucibely materials on has used all reasonable care to ensure the information mel			

liability can be accepted by Heidelberg Materials UK for any loss, damage, cost or expense arising from any inaccuracy, whether due to negligence

Signed:

10 ardial

Dr Nina Cardinal, Dipl.Ing., CEng, MICT National Technical Manager

UK

1333-CPR-00134