

## **Conformity Certificate**



## Regen Ground Granulated Blastfurnace Slag Produced at Sample Period

Teesside January 2025

## **Certificate of Conformity of Regen GGBS**

Spot samples of Regen GGBS were taken and tested to determine conformity to the autocontrol requirements of EN 15167-1 "Ground granulated blastfurnace slag for use in concrete, mortar and grout" following the methods given in that standard. The values reported are mean values for the monthly production period.

·			
		Result	EN Limit
Regen GGBS Only			
Fineness m <sup>2</sup> /kg		455	min. 275
Magnesia MgO %		7	max. 18
Sulfate SO <sup>3</sup> %		0.03	max. 2.5
Sulfide S <sup>2-</sup> %		0.75	max. 2.0
Chloride Content Cl %		0.00	max. 0.1
Moisture Content %		0.13	max. 1.0
Aluminia Al <sub>2</sub> O <sub>3</sub> %		15	
Note: If the value is $\ge$ 14% the '+SR' restriction will be exceeded if the $C_3A$ of the	CEM I is > 10	%.	
Alkalis as Na2O equ. (acid soluble)			
Certified Average Alkali (Last 25) %		≤ 1.0	
Mean Alkali content (Last 25) %		0.41	
Declared Mean: Mean last 25 + (SD last 25 x 1.64) %		0.47	
Combination of 50% Laboratory Stock CEM I Portland Cement a	and 50% Reg	en GGBS	
Initial Setting Time min.		227	> 2 x PC
Activity Index %	7 days	71	min. 45
	28 days	89	min. 70
Laboratory Stock CEM I Portland Cement O	nly	•	•
The laboratory stock CEM I Portland cement used in these tests was supplied	ed by Heidelb	erg Materia	ls UK.
Initial Setting Time min		148	
Compressive Strength N/mm <sup>2</sup>	7 days	46.8	
	28 days	59.4	
The Regen GGBS contained no additional materials other than those permitted demonstrate the conformity of the material sold during the month to the release by materials of this used an least name to ensure the information never community is			

liability can be accepted by Heidelberg Materials UK for any loss, damage, cost or expense arising from any inaccuracy, whether due to negligence

Signed:

10 and al

Dr Nina Cardinal, Dipl.Ing., CEng, MICT National Technical Manager

CE

1333-CPR-00212